



Certificate of Compliance

Certificate: 2573185

Master Contract: 223369

Project: 70133804

Date Issued: 2017-06-07

Issued to: **Hanbay Inc**
115 Gun Ave
Pointe-Claire, Quebec H9R 3X2
CANADA
Attention: Hans Baumann

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Aisha Sreenath*
Aisha Sreenath

PRODUCTS

CLASS - C441802 - OUTLET BOXES AND FITTINGS-Boxes - For Hazardous Locations

CLASS - C441882 - OUTLET BOXES AND FITTINGS-Boxes - For Hazardous Locations - Certified to US Standards

Class I, Div 1, Groups B, C and D; Class II, Groups E, F and G;

Enclosure model Rxx-B for use in hazardous locations.

APPLICABLE REQUIREMENTS

CAN/CSA Std. C22.2 No. 0-M91 (R2001) -	General Requirements - Canadian Electrical Code, Part II
CSA Std C22.2 No. 25-1966	- Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
CSA Std C22.2 No. 30-M1986	- Explosion-Proof Enclosures for Use in Class I Hazardous Locations
UL 1203 - 2006	- Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 2573185

Master Contract: 223369

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70133804	2017-06-07	Update to report 2573185 allow the option of using an alternate material for the enclosure cover and enclosure base.
70018830	2015-01-23	Report update to address outstanding issues listed on previous inspection report (date 07-May-2014)
2573185	2013-03-06	Certification of the enclosure model Rxx-B for hazardous locations.