



National Technical Systems Canada Inc.

2425 Boulevard Industriel
Chambly, QC
J3L 4W3, Canada
Phone: 450-868-0360
Fax: 450-868-0351

TEST CERTIFICATE

Product Name: M-Series Valve Actuators

Manufacturer: Hanbay Inc.

Part No.: M-Series - Standard Valve Actuator & Manual Overdrive Valve Actuator

Serial Number: N/A

Applicant: Hanbay Inc.

We, National Technical Systems Canada Inc. declare that the product above has been tested in our facility and found compliance with the applicable essential requirements of standards herein specified.

Note:

- Tests were performed on February 16th, 17th, 18, 21st & 22nd 2022
- No modifications have been incorporated in the product during the qualification tests.
- All information's about the qualification tests are presented in the test report **FTR0607834**.
- This test certificate do not in any situation, supersede official test report **FTR0607834**.

Test Name Standards	Test Specifications	Results
Ingress protection against access to hazardous parts Standard IEC 60259:2013	Code IP6x	PASS
Ingress protection against solid foreign objects Standard IEC 60259:2013	Code IP6x	PASS
Ingress protection against water Standard IEC 60259:2013	Code IPx5	PASS
Ingress protection against water Standard IEC 60259:2013	Code IPx6	PASS



**Alexandre Beausoleil, P. Eng. /
ENV & DYN Lab. Manager**