


Statement of compliance

Project information

Nemko project number	462209	Nemko certificate number	462209SOCSTD1
Nemko test report numbers	354424-1TRFEMC		
	462209-1TRFEMC		
	424306-1TRFEMC		
	424306-2TRFEMC		

EUT information

Applicant (name and address)	Hanbay Inc 135 Brunswick blvd. Pointe Claire, QC, Canada, H9R 5N2	Manufacturer (name and address)	Hanbay Inc 135 Brunswick blvd. Pointe Claire, QC, Canada, H9R 5N2
Product name	Miniature Electric Valve Actuator	Models	MDM and RCM
		Model variant(s):	RCx, RDx, MDx, MCx
Serial number(s)	RCM: 1801-T1 MDM: 1801-T2	Trademark	

Declaration

Relevant standard(s) against which equipment was tested	EN 61326-1: 2013 (Group 1, Class A; industrial electromagnetic environment)
	FCC 47 CFR Part 15, Subpart B – Verification, Class A
	ICES-001 Issue 5 July 2020, Class A
	IEC 61000-6-2:2016
	IEC 61000-6-4:2018

Statement



NEMKO CANADA INC. states that the equipment under test **COMPLIED** in all respects with the appropriate requirements of the standard(s) listed above.

Note: Please refer to the above referenced test report(s) for any conditions pertaining to compliance.

Date of issue: November 21, 2022

David Duchesne, EMC/RF Lab Manager

Prepared by:



Signature